


7. WATER MAINS SHALL BE LAID TO PROVIDE A VERTICAL SEPARATION OF AT LEAST 18" BETWEEN THE BOTTOM OF THE WATER MAIN AND THE TOP OF THE SANITARY SEWER AND STORM DRAINAGE. WATER MAINS SHALL BE INSTALLED ABOVE SEWERS.
8. STORM DRAINAGE SHALL BE LAID TO PROVIDE A VERTICAL SEPARATION OF AT LEAST 6".



MATCH LINE - SHEET C-12

STAMP

State of Florida
Professional Engineer
License No. 50588

TIM J. HALL, P.E.

NOV 29 2010

DRAWN BY KEITH AND SCHNARS, PA: FL
CHECKED BY T.J.H.
ISSUE DATE OCTOBER 18, 2010
JOB NUMBER 17796.42
SHEET NAME PRELIMINARY WATER & SEWER PLAN
SHEET NUMBER C-10

C-10