



- LEGEND**
- o- EXISTING SANITARY SEWER SYSTEM.
 - o- EXISTING WATER DIST. SYSTEM.
 - 3 PROPOSED GRAVITY SEWER SYSTEM EXTENSION
 - † PROPOSED WATER DIST. SYSTEM EXTENSION FIRE HYDRANT AND VALVE.
 - TYPICAL GATE VALVE LOCATION.
 - TYPICAL SINGLE SEWER LATERAL SYMBOL.
 - TYPICAL DOUBLE WATER SERVICE SYMBOL.
 - TYPICAL DOUBLE SEWER LATERAL SYMBOL.
 - TYPICAL SINGLE WATER SERVICE SYMBOL.
 - TYPICAL FIREHYDRANT SYMBOL.

SPECIFICATIONS:

1. WATER LINES TO BE DUCTILE IRON PIPE
2. WATER MAINS TO BE 30" DEER
3. SEWER LINES TO BE ASTM D-3039, SDR 35.
4. TERMINAL MANHOLES TO BE 4.0 FT DEEP TO INVERT.
5. GRAVITY SEWER SLOPES TO BE 0.3%, EXCEPT THAT UPPER 400' ARE TO BE AT 0.4%.
6. FIRE HYDRANTS TO BE LOCATED IN SWALE AREA, 7 FT FROM EDGE OF PAVEMENT.

NOTES:

1. ELEVATIONS REFER TO 1924 NGVD.
2. WATER AND SEWER MAINS LOCATED IN PRIVATE ROADS OR IN PRIVATE PROPERTY SHALL BE IN EASEMENTS DEDICATED TO THE CITY OF COCONUT CREEK.
3. MANHOLES' RIM ELEVATIONS TO BE DETERMINED BY P&D PLAN.
4. SEWER'S INVERT ELEVATIONS SHOWN ON PLAN ARE FOR LONGEST CRITICAL RUN. ALL OTHER RUNS ARE NOT CRITICAL.

DESIGNED: <i>Rob</i>							
DRAWN: M.C.C.							
CHECKED:							
	NO.	DATE	APP.	REVISION	NO.	DATE	APP.

LUDOVICI & ORANGE
CONSULTING ENGINEERS INC.
 329 PALERMO AVENUE, CORAL GABLES, FLORIDA 33134

WINSTON PARK	TRACT "F"	SCALE: 1"=60'	SHEET: 2
JOSHUA MUSS AND ASSOCIATES	PRELIMINARY WATER & SEWER LAYOUT	DATE: 9-1-87	PROJECT NO. 8431 G