


- RECORD DRAWING REQUIREMENTS:**
1. WATER AND SEWER AS-BUILT DRAWINGS AND DISKETTES SHALL BE SUBMITTED TO THE CITY AFTER COMPLETION OF THE PROJECT. AS-BUILT DRAWINGS SHALL CONSIST OF:
 - A. FOUR (4) COMPLETED, FULL SETS OF BLUEPRINTS, SIGNED & SEALED.
 - B. ONE (1) FULL COMPLETED, SETS OF MYLARS.
 2. AS-BUILT INFORMATION SHALL INCLUDE:
 - A. DISTANCE AND OFFSET FROM A REFERENCED POINT FOR WATER MAIN, FITTINGS, VALVES, SERVICE LINES, BLOW OFFS, FIRE HYDRANTS, ETC.
 - B. ELEVATION OF TOP OF PIPE FOR WATER MAIN AND FORCE MAIN AT 50 FOOT INTERVALS, FITTINGS, VALVES, AND PIPE AT CROSSINGS.
 - C. ELEVATION OF MANHOLE RIMS AND INVERTS.
 - D. DISTANCE OF SEWER PIPE BETWEEN MANHOLES.
 - E. TYPE OF MATERIALS INSTALLED INCLUDING LOCATIONS OF CHANGE OF MATERIALS.



1. REQUIREMENTS APPLY TO FIRE HYDRANTS, SIAMSE CONNECTIONS, AND ANY OTHER FIRE EQUIPMENT FOR UTILIZING FIRE HOSE, ON PUBLIC OR PRIVATE PROPERTY.
2. BY THE AUTHORITY OF THE SOUTH FLORIDA FIRE PREVENTION CODE SECTION 5211.2.
3. THE DIAGRAM SHALL APPEAR ON ALL LANDSCAPE AND ENGINEERING PLANS PRIOR TO APPROVAL.
4. THE CLEAR ZONES SHALL BE DESIGNED AND KEPT FREE OF LANDSCAPE (EXCEPT SOD), MAILBOXES, PARKING, LAMP POSTS, AND ALL OTHER OBJECTS.
5. EXCEPTIONS: OTHER FIRE FIGHTING EQUIPMENT, OR TRAFFIC POSTS TO PROTECT FIRE FIGHTING EQUIPMENT.

48 HOURS BEFORE DIGGING
CALL SUNSHINE
 TOLL FREE
1-800-432-4770
 UNDERGROUND UTILITIES NOTIFICATION
 CENTER OF FLORIDA

- SPECIFIC NOTES:**
1. ALL WATER MAINS SHALL BE DIP CLASS 51 OR HIGHER MEETING AWWA SPECIFICATIONS C-151 OR C-106 LATEST PROVISIONS. THE CITY OF COCONUT CREEK INSPECTOR MUST BE PRESENT FOR ALL DENSITIES.
 2. DENSITY TESTS SHALL BE PERFORMED BY A CERTIFIED GEOTECHNICAL ENGINEERING FIRM DURING INSTALLATION OF THE UTILITIES.
 3. REFER TO BOUNDARY & TOPOGRAPHIC SURVEY FOR EXISTING LOCATIONS & TOPOGRAPHIC CONDITIONS.

CITY OF COCONUT CREEK NOTE:

1. NO VALVES, METERS, FIRE HYDRANTS, CLEANOUTS, MANHOLES, OR OTHER UTILITY APPURTENANCES ARE TO BE PLACED IN, OR ADJACENT TO SIDEWALKS, CURBS, PARKING SPACES OR OTHER SUCH SITE FEATURES SO AS TO PRESENT A HAZARD OR RESTRICT THE MAINTENANCE OR OPERATION OF THE UTILITY INFRASTRUCTURE.

TOPOGRAPHY NOTE:

1. ALL EXISTING AND PROPOSED ELEVATIONS ON THIS PLAN ARE IN NAVD. TO CONVERT TO NGVD, ADD 1.55.

PROJECT: IN THE PINES		TITLE: WATER DISTRIBUTION SYSTEM PLAN	
DATE: 05/15/14	REVISIONS		
SCALE: 1" = 30'	DATE	COMMENTS	
DRAWN BY: HEJ	09/01/14	MODIFY PER CITY SP DRC #1	
CHECKED BY: LJJ	10/25/14	REVISE PER CITY SP DRC COMMENTS #2	
APPROVED BY: HEJ			
PROJECT #: 13-0020			
AJ HYDRO ENGINEERING, INC. 5932 NW 73RD COURT PARKLAND, FL 33067 TEL (954) 344-7866 FAX (954) 344-7866		SHEET NUMBER WS2 OF 2	

HOWARD JABLON, P. E. #47514 DATE