


NW 51ST TERRACE

PHOTOMETRIC POINT-BY-POINT SITE PLAN
SCALE: 1"=20'-0"



Symbol	Label	Catalog Number	Description	Lamp	File	Lumens	LLF	Watts
■	SA	T10R10P**AMS2**	TOWN AND COUNTRY GE LIGHTING	1: 150W PMH, CLEAR B017, HORIZ	GE451462.IES	12900	0.8	122
■	SB	RL52BANN1ANN80AN	ACORN TYPE PHILIPS-HADCO LIGHTING	80 LED REBELS 4000K TYPE-V	RL525V4K803CN11.IES	6700	0.9	85
●	SF	802-PT-TS-CFL/1-42W/TT-MT-BM-BM-10	POST TOP LUMINAIRE COOPER / SHAPER LIGHTING	1: CFL, 42W TT 4-PIN, GX24q-4	802-PT-LCS.IES	3200	1.0	42

STATISTICS					
Description	Avg	Max	Min	Max/Min	Avg/Min
SITE	2.07 fc	5.3 fc	0.4 fc	13.25:1	5.18:1
PARKING & DRIVE	1.93 fc	4.3 fc	0.5 fc	8.60:1	3.86:1
POOL SURFACE & DECK	4.17 fc	5.3 fc	3.0 fc	1.77:1	1.39:1
PEDESTRIAN PATH #1	1.05 fc	1.7 fc	0.4 fc	4.25:1	2.63:1
PEDESTRIAN PATH #2	1.20 fc	3.9 fc	0.4 fc	9.75:1	3.00:1
PEDESTRIAN PATH #3	2.14 fc	4.3 fc	0.5 fc	8.60:1	4.28:1
PEDESTRIAN PATH #4	1.47 fc	3.4 fc	0.5 fc	6.80:1	2.94:1



NOTE
THESE DRAWINGS ARE PREPARED PER ESTABLISHED INDUSTRY STANDARDS AND REPRESENT THE ENGINEERS DESIGN CONCEPT. THEY ARE NOT INTENDED TO PROVIDE EVERY DETAIL OR CONDITION REQUIRED TO CONSTRUCT THE BUILDING. THE CONTRACTOR THROUGH SUBMITTALS AND OTHER COORDINATION EFFORTS IS FULLY RESPONSIBLE FOR PROVIDING A COMPLETE AND OPERATIONAL BUILDING WHETHER INDICATED ON THE PLANS OR NOT.

Revision	Date	Description
1	10-26-2012	MOVED LIGHTING FIXTURES AS PER REVISED SITE PLAN
2	2-28-2013	OVERALL SITE PLAN ADJUSTMENT & ADDED LIGHTING FIXTURES
3	4-24-2013	DEVELOPMENT REVIEW COMMITTEE REPORT #4 COMMENTS

HYAC PLUMBING ELECTRICAL
THOMPSON & YOUNGROSS ENGINEERING CONSULTANTS, LLC
CERTIFICATE OF AUTHORIZATION NO. 25996
112 Southeast 10th Street, Delray Beach, Florida 33483
V: 561.274.0200 F: 561.274.0222 E: tec@tecfca.com www.tecfca.com

LONG PINES RESIDENTIAL DEVELOPMENT
COCONUT CREEK FLORIDA

Plot Date: 8-3-2012
Xref(s): 12087_BS
Cadd File: 12087_PHOTO#2
Design By: MDT
Drawn By: MDT/AJY
Checked By: MDT/AJY
Date Issued: 8-3-2012
Scale: 1"=20'-0"
Sheet: 1
Of: 2

