



PLANNING NOTES

ALL WEARING SURFACER SHALL BE 1" THICK ASPHALTIC CONCRETE TYPE S-1 OVER TACK COAT, OVER PRIME AND SAND SEAL.

ALL BASE COURSE SHALL BE LIMEROCK GRADE COMPACTED IN ACCORDANCE WITH A. A. S. H. T. O. T-180 TO 98% MIN. DENSITY.

SUBGRADE 12" BELOW BASE COURSE SHALL BE COMPACTED IN ACCORDANCE WITH A. A. S. H. T. O. T-180 TO 98% MIN. DENSITY.

THE ENTIRE R/W SHALL BE STABILIZED AS PER CITY SPECIFICATIONS. ALL FILL SHALL BE COMPACTED TO 95% OF MIN. DENSITY PER A. A. S. H. T. O. T-180.

Site Enlargement Plan

Site Drainage Plan

NOTES:
 THE UTILITIES FOR WATER SERVICE AND SANITARY SEWER WERE LOCATED AT THE FRONT OF THE PARCEL AND MODIFICATION SHOULD NOT BE REQUIRED.

Handwritten signature and date: 9/21/92

Revisions	Checked By
Date	9-21-92
Project	121-92
Sheet	2 of 2

LYONS PLAZA