CITY OF COCONUT CREEK DEVELOPMENT REVIEW COMMITTEE REVIEW COMMENTS #2 JUNE 1, 2011

Project Name: Project Location: Review/Application: Control/Permit No: Simonton Court South side of Hillsboro Blvd, between NW 39th Ave and Lyons Rd Administrative Approval PZ-11040007

PLANNING & ZONING:

Advisory Comment – Site

1. Sec.13-241(b) - All sidewalks and sidewalk connections shall be a minimum five (5) feet in width.

ENGINEERING:

Condition of Approval

1. Proposed concrete benches, sidewalks, and their appurtenances not to encroach 20 feet Lake Maintenance Easement or Utility easements.