## CITY OF COCONUT CREEK DEVELOPMENT REVIEW COMMITTEE REVIEW COMMENTS #2 MAY 9, 2011

Project Name: Project Location: Review/Application: Control/Permit No: <u>Village Shoppes of Coconut Creek</u> 4690 N. State Road 7, Coconut Creek, FL Administrative Approval PZ-11040004</u>

## ENGINEERING:

Conditions of Approval

- 1. Proposed playground equipment, bollards, concrete footings, and any other permanent improvements shall not encroach existing utility easements and must maintain a minimum horizontal separation of 6 feet from all water and sewer lines.
- 2. Easement Agreement for fence only to be provided at time of building permit review.

## LANDSCAPE ARCHITECTURE:

Condition of Approval

1. Existing landscaping must not be impacted as a result of this project.